



Certificate of Conformity



Global-Mark Pty Ltd,
Suite 4.07, 32 Delhi
Road, North Ryde
NSW 2113, Australia

Tel: +61 (0)2 9886
0222 - www.Global-Mark.com.au

Certificate Holder:
Termstop Pty Ltd
3 Heritage Retreat
Harrington Park, NSW
2567
Tel: 0419 191 340

Certificate number: CM30004 Rev1

THIS TO CERTIFY THAT

Termstop Colar

Type and/or use of product:

Termite Collar is used to block concealed termite entry to structures via the shrinkage crack formed between the concrete slab and pipe penetrations.

Description of product:

Termite Collar consisting of an injection moulded PVC "collar" made of UPVC D80 hardness (instantaneous); at least 1mm thick. The collar is manufactured to fit outside a PVC drainage pipe, having a nominal internal diameter of 40, 50, 80, 100mm.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA (edition)

	Volume One		Volume Two	
Performance Requirement(s)			3.1.3.3 (b)(i)	Termite management systems
Deemed-to-Satisfy Provision(s):	B1.4 (i)	Determination of structural resistance of materials and forms of construction –Termite Risk Management	3.1.3.3 (c)	Termite management systems durable notice
			QLD 3.1.3.3 (b)(i)	Termite management systems
State or territory variation(s):	NT B1.4 (i) (i)	Determination of structural resistance of materials and forms of construction Termite Risk Management Note: In the NT 3660.1:2000 remains applicable	QLD 3.2.3.2(d)(ii)	A design life of at least 50 years
	NT B1.4 (i) (iii)	Termite management systems durable notice	QLD 3.1.3.3 (c)	Termite management systems durable notice

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate. The purpose of Global-Mark **construction site audits** is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In placing **the CodeMark mark** on the product/system, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the **expertise of external bodies** (laboratories, and technical experts).


Herve Michoux
Global-Mark Managing Director


Peter Gardner
Unrestricted Building Certifier

Date of issue: 11/04/2018

Date of expiry: 11/04/2021





CODEMARK
Australia

Certificate of Conformity

			3.1.3.3 (b)(i)	Termite management systems
SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B				
Limitations and conditions:				Building classification/s:
<p>The durable notice installed in accordance with -Volume One: B1.4(i)(ii) and State Variation Volume One -NTB1.4(i)(iii) and Volume Two: 3.1.3.3(c) and State Variation Volume Two – QLD 3.1.3.3(c) must be permanently fixed to the building in a prominent location, such as a meter box or the like indicating:</p> <ul style="list-style-type: none"> a. The method of termite risk management; and b. The date of installation of the system; and c. The manufacturer’s recommendations for the scope and frequency of future inspections for termite activity. <p>Can only be installed as a embedded in the slab, pre-pour, as per Figure 5.3 Option B of AS3660.1: 2014 When used as a termite barrier in conjunction with a concrete slab the slab must be designed and constructed according to AS 2870: 2011 or AS 3600: 2009 (up to amendment 1, 2010).</p>				1, 2, 3, 4, 5, 6, 7, 8, 9 & 10

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

See type and/or use of product on page 1

A2 Description of product

See Description of product on page 1

A3 Product specification

TermStop Collar Manual, Version 2

A4 Manufacturer and manufacturing plant(s)

Australian Plastics and Engineering
3/8 Ramly Drive
Burleigh Head, QLD
Australia

A5 Installation requirements

Product installation, shall be carried out by a competent person:
As per the TermStop Collar Manual, Version 2; and
Have ready access to all to the relevant technical information related to the product use

A6 Other relevant technical data

Nil



Certificate of Conformity

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

The following assessment methods have been used to determine compliance with NCC 2016:

Code Clause	Assessment Method(s)	Evidence of suitability	Evidence reference in B2
NCC Volume One B1.4 (i)	A0.5 (a)	A2.2 (a)(iv) – Test report and A2.2 (a)(vi) – Other forms of documentary evidence	Items 1 to 2
NCC Volume Two 3.1.3.3 (b)(i) and 3.1.3.3 (c)	1.0.5 (a)	1.2.2 (a)(i) – Test report and 1.2.2 (a)(iv) – Other forms of documentary evidence	Items 1 to 2

B2 Reports

The following reports have been used as evidence to determine compliance with NCC 2016:

Ref	Author	Reference	Date	Description	Type of Evidence	NATA Registration
1	ExcelPlas	Report # 7366	22/3/2018	Technical Report - Durometer Hardness Shore D– Accredited Laboratory –ExcelPlas.	A2.2 (a) (iv) & 1.2.2 (a) (i)	17149
2	TermStop	TermStop Collar Manual	V2	TermStop Collar Manual	A2.2 (a)(vi) and 1.2.2 (a)(iv)	NA

End of document